

SaferFarm.org – Farm Hazard Analysis Tool

Ag Buildings

Roof Bracing Snow Load

Least Protection

1. No lateral bracing of bottom chord or web members; trusses built and installed by owner.
2. Lateral bracing of bottom chord members to manufacturer's specifications but not top chord or web members; bracing not installed to engineer's specifications; installed by owner or non-certified builder.
3. Lateral bracing of bottom chord members but not top chord or web members and not to manufacturer's specifications; some bracing installed to engineer's specifications; installed by non-certified builder.
4. Lateral bracing of top and bottom chord members but not web to manufacturer's specifications; some bracing installed to engineer's specifications; installed by certified builder.
5. Lateral bracing of top and bottom chord members and web to manufacturer's specifications; all bracing installed to engineer's specifications; installed by certified builder.

Most Protection



Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____