

SaferFarm.org – Farm Hazard Analysis Tool

Other Structures/Accessories

Fuel Tank Accessories

Least Protection

1. Installed by owner or non-certified vendor; single-walled AST but no pressure-vacuum relief valve; not reflectively painted with fuel type and warning label.
2. Installed by owner or non-certified vendor; single-walled AST with pressure-vacuum relief valve; not reflectively painted with fuel type and warning label.
3. Installed by owner or non-certified vendor; single-walled AST with pressure-vacuum relief valve; not reflectively painted, but has fuel type and warning label, Flammable--Keep Fire and Flame Away or equivalent
4. Installed by certified tank contractor; double-walled AST with overfill alarm, automatic shut-off and pressure vacuum relief valve; not reflectively painted with fuel type and warning label, Flammable--Keep Fire and Flame Away or equivalent
5. Installed by certified tank contractor; double-walled AST with overfill alarm, automatic shut-off and pressure vacuum relief valve; reflectively painted with fuel type and warning label, Flammable--Keep Fire and Flame Away, or equivalent.

Most Protection



Item:	Item:	Item:	Item:	Item:
<input type="radio"/> O1	<input type="radio"/> O1	<input type="radio"/> O1	<input type="radio"/> O1	<input type="radio"/> O1
<input type="radio"/> O2	<input type="radio"/> O2	<input type="radio"/> O2	<input type="radio"/> O2	<input type="radio"/> O2
<input type="radio"/> O3	<input type="radio"/> O3	<input type="radio"/> O3	<input type="radio"/> O3	<input type="radio"/> O3
<input type="radio"/> O4	<input type="radio"/> O4	<input type="radio"/> O4	<input type="radio"/> O4	<input type="radio"/> O4
<input type="radio"/> O5	<input type="radio"/> O5	<input type="radio"/> O5	<input type="radio"/> O5	<input type="radio"/> O5

Farm: _____

Inspector: _____

Date: _____