

# SaferFarm.org – Farm Hazard Analysis Tool

## Ag Buildings

### Fire Detection/Suppression

#### Least Protection

1. No smoke or heat detector of any type utilized, or battery has discharged and not been replaced; lacking fire resistive construction; no fire extinguishers.
2. Smoke detector placed in farm office only; detector service or replacement schedule unknown; no fire resistive construction; ABC type fire extinguisher equipped.
3. Owner installed smoke and/or heat detectors; no suppression system; detector serviced yearly; fire resistive construction, but no firewall/roof-fire-vent; ABC type fire extinguisher mounted at exits.
4. Professionally installed and monitored fire detection; no suppression system; fire resistive construction with firewall and roof fire-vents; ABC type fire extinguisher mounted at exits.
5. Professionally installed and monitored fire detection and suppression system; fire resistive construction with firewall and roof fire-vents; ABC type fire extinguisher mounted at exits.

#### Most Protection



Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: \_\_\_\_\_

Inspector: \_\_\_\_\_

Date: \_\_\_\_\_