

# SaferFarm.org – Farm Hazard Analysis Tool

## Ag Buildings

### Fire Extinguishers

#### Least Protection

1. Fire extinguishers are not charged, are missing, or have never been there.



2.



3. Only one 10-pound ABC type extinguisher is available or charged; extinguisher is not easily accessible, not mounted; only Class A or Class BC extinguishers are present.

4.



5. A 10-pound ABC type extinguisher is accessible on each floor of a building or within 50 feet of a structure; is mounted; fully charged.

#### Most Protection

Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: \_\_\_\_\_

Inspector: \_\_\_\_\_

Date: \_\_\_\_\_