

SaferFarm.org – Farm Hazard Analysis Tool

Ag Buildings

Flammable Liquid Storage

Least Protection

1. Flammable and combustible liquids stored on open shelves, or on the ground or floor.
2. Flammable and combustible liquids stored in wooden cabinet.
3. Flammable and combustible liquids stored in metal, non-self closing, unlocked cabinet.
4. Flammable and combustible liquids stored in metal, self-closing, unlocked cabinet.
5. Flammable and combustible liquids stored in metal, self-closing, locked cabinet.

Most Protection



Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____