

# SaferFarm.org – Farm Hazard Analysis Tool

## B&B Residential

### Fire Detection/Suppression (City Water)



#### Least Protection

1. No working smoke or fire detection system; no sprinkler system; smoking not restricted; no fire escape/floor plan in each guest room; ABC fire extinguisher is available, but not visible.
2. Battery powered, smoke detection system only; no sprinkler system; smoking restricted to specific areas; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits only.
3. Battery powered, smoke and heat detection system; no sprinkler system; no smoking permitted; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits and heating and cooking
4. Electrically wired, battery back-up, on-site smoke and heat detection system; kitchen sprinkler system; no smoking permitted; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits and heating
5. Professionally installed and monitored fire detection and sprinkler system; no smoking permitted; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits.



#### Most Protection

Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: \_\_\_\_\_

Inspector: \_\_\_\_\_

Date: \_\_\_\_\_