

# SaferFarm.org – Farm Hazard Analysis Tool

## B&B Residential

### Fire Detection/Suppression

#### Least Protection

1. No smoke or heat detectors used or battery power supply has discharged; no fire extinguisher or discharged fire extinguisher.
2. Smoke detector, but not heat detector located near heating areas, cooking areas, but not in bedroom areas; detector service or replacement schedule unknown; ABC fire extinguisher in kitchen area only.
3. Smoke and heat detectors placed in heating, cooking, and each sleeping area; detectors professionally serviced yearly; no sprinkler system; ABC fire extinguisher in kitchen and bedroom hallways.
4. Professionally installed and monitored fire detection and sprinkler system; sprinkler system located in kitchen area of the home only; ABC fire extinguishers in kitchen and heating area.
5. Professionally installed and monitored fire detection and sprinkler system; easily accessible ABC fire extinguishers on each floor of house.

#### Most Protection



Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm:

Inspector:

Date: