

SaferFarm.org – Farm Hazard Analysis Tool

B&B Residential

Power Outage



Least Protection

1. No power outage protection available.
2. Flashlights provided in each room; batteries may not be fresh.
3. Battery supplied power source available; regular operation check; emergency exit and/or hallway/stairway lighting supplied; flashlights with fresh batteries located in each room and public area.
4. Small gas engine powered generator available; regular operation check; manual transfer switch to disconnect from main power distribution line; rural water supply pump and some lighting supplied.
5. Automatic power generator professionally installed; operation tested semi-annually; automatic transfer switch to disconnect from main power distribution line; alarms sounded when operating; entire home serviced.

Most Protection

Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____