

# SaferFarm.org – Farm Hazard Analysis Tool

## B&B Residential

### Roof



#### Least Protection

1. Stapled 240 lb/square asphalt shingles or nailed wooden shingles or re-roofed nailed asphalt shingles; non-ventilated roof cavity; no drip edge barrier installed; roof installed by owner or non-certified roofing contractor.
2. Nailed 240 lb/square asphalt shingles; ventilated roof cavity; drip edge barrier installed; roof installed by owner or non-certified roofing contractor.
3. Nailed laminated fiberglass shingles or nailed 300 lb/square asphalt shingles; ventilated roof cavity; drip edge barrier installed; roof installed by bonded, certified, professional roofing contractor.
4. Nailed slate roof over reinforced truss rafters; ventilated roof cavity; drip edge barrier installed; roof installed by bonded, certified, professional roofing contractor.
5. Nailed clay tile or rust-resistant, clad-metal roofing; ventilated roof cavity; drip edge barrier installed; roof installed by bonded, certified, professional roofing contractor.

#### Most Protection

Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: \_\_\_\_\_

Inspector: \_\_\_\_\_

Date: \_\_\_\_\_