

SaferFarm.org – Farm Hazard Analysis Tool

Other Structures/Accessories

Above Ground Fuel Storage

Least Protection

1. Gasoline tank is located next to buildings or other structures; tanks do not have double wall or spill and leak containment; tanks unprotected from vehicular contact; tanks rusted with signs of leakage.
2. Gasoline tank is located less than 40 feet from other buildings or structures; tanks do not have double walls or spill and leak containment; tanks unprotected from vehicular contact; some signs of leakage.
3. Gasoline tank is located at least 40 feet from other buildings or structures; some tanks without double walls or spill and leak containment; all tanks protected from vehicular contact ; no sign of leakage.
4. Gasoline tank is located at least 40 feet from other buildings or structures; all tanks have double walls and spill and leak containment; all tanks protected from vehicular contact in heavy ; no sign of leakage.
5. Gasoline tank is located at least 40 feet from other buildings or structures; all tanks have double walls and spill and leak containment; all tanks protected from vehicular contact; no signs of leakage.

Most Protection



Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____